

कार्यालय - अमरावती महानगरपालिका अमरावती  
विभागाचे नांव - प्रकाश विभाग  
दर सूचना (कोटेशन नोटीस)

अमनपा/प्रवि/शअ/ 675 /2025  
दिनांक:- 19 /06/2025.


अमरावती महानगरपालिके अंतर्गत दर सूची बाह्य दर निश्चित करण्यासाठी खालील बाबींकरीता मान्यता प्राप्त उत्पादक किंवा वितरक यांचेकडून दराबाबत दरपत्रक (कोटेशन) मोहोरबंद लिफाफ्यामध्ये अथवा ई- मेलद्वारे मागविण्यात येत आहे.

AMRAVATI MUNICIPAL CORPORATION, AMRAVATI				
Electrical Department				
Name of Work - Providing D.G.Set for external supply arrangement at Fishery hub project.				
Non- CSR Item List				
Item No	Category	Description	Unit	Rate
1	NCSR	Supply of diesel generating set with alternator of 140 KVA confirming to CPCB –IV plus Emission Compliant with output continuous rating,3 phase,415V, 50 c/s 0.8 p.f.A.C supply,a totally enclosed liquid cooled multi in line cylinder diesel engine developing suitable BHP at 1500 rpm with 10% overload for 1 hour in 12 hours,along with standard accessories,self excited,self regulated,screen protected alternator with static excitation system running at 1500 RPM as per IS:4722-2001 with voltage regulation +/-0.5 %,with performance class G2.Both the engine and alternator directcoupled on a common fabricated steel base frame and mounted on anti-vibrating pads without standard control panel comprising meters,switchgears,indicators connected with suitable wires/cables,the complete set enclosed in composite Acoustic enclosure as fully assembled integral unit made of 16 SWG CRCA sheet,sound absorbing material to restrict sound level upto 75 dB at 1.0 m with suitable capacity DEF tank provided with firstfilling of oil. Diesel tank capacity not less than 290 Liters etc.on provided M20 grade CC Foundation and obtaining necessary approval from Electrical Inspector if necessary.This D.G.Set is fitted in sound proof & Weather proof Acoustic Enclosure as per CPCB – IV plus Emission Compliant (with acoustic enclosure as per latest Government norms) approved Norms.	Each	
2	NCSR	Supply of diesel generating set with alternator of 160 KVA confirming to CPCB –IV plus Emission Compliant with output continuous rating,3 phase,415V, 50 c/s 0.8 p.f.A.C supply,a totally enclosed liquid cooled multi in line cylinder diesel engine developing suitable BHP at 1500 rpm with 10% overload for 1 hour in 12 hours,along with standard accessories,self excited,self regulated,screen protected alternator with static excitation system running at 1500 RPM as per IS:4722-	Each	

	2001 with voltage regulation $\pm 0.5\%$ , with performance class G2. Both the engine and alternator directcoupled on a common fabricated steel base frame and mounted on anti-vibrating pads without standard control panel comparising meters, switchgears, indicators connected with suitable wires/cables, the complete set enclosed in composite Acoustic enclosure as fully assembled integral unit made of 16 SWG CRCA sheet, sound absorbing material to restrict sound level upto 75 dB at 1.0 m with suitable capacity DEF tank provided with firstfilling of oil. Diesel tank capacity not less than 290 Liters etc. on provided M20 grade CC Foundation and obtaining necessary approval from Electrical Inspector if necessary. This D.G. Set is fitted in sound proof & Weather proof Acoustic Enclosure as per CPCB – IV plus Emission Compliant (with acoustic enclosure as per latest Government norms) approved Norms.		
--	--	--	--

दरपत्रक सादर करण्याचा कालावधी	दि. 19 / 06 / 2025 ते दि. 26 / 06 / 2025 सायंकाळी 5.00 वाजेपर्यंत
दरपत्रक सादर करण्याचे ठिकाण	प्रकाश विभाग, महानगरपालिका अमरावती
ई-मेल आयडी	ee1pwdamc@gmail.com
दूरध्वनी क्रमांक	0721-2576482.

- टिप:- 1) दर वस्तु व सेवा कर विरहीत (Exclusive G.S.T) देण्यात यावे.
- 2) दरपत्रक सादर करण्याकरीता मान्यताप्राप्त उत्पादक किंवा वितरक असल्याबाबतचे प्रमाणपत्र जोडणे आवश्यक आहे.
- 3) दरपत्रक सादर करण्याचा कालावधी नंतर प्राप्त झालेले दरपत्रक ग्राह्य धरण्यात येणार नाही.

  
 शहर अभियंता  
 महानगरपालिका, अमरावती